



Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/VP3235HS
Name of operator	Farmers Boy Deeside
Location of Facility	10 th Ave Deeside Ind Park Deeside Flintshire
Time and date of the detection	6/6/13 2pm

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	6/6/13 at 2pm
Reference or description of the location of the event	Northwest corner onto neighbouring property
Description of where any release into the environment took place	Hot weather conditions at time evaporated water
Substances(s) potentially released	Fresh water with potentially 50ppm of disinfectant
Best estimate of the quantity or rate of release of substances	Insignificant, hot weather conditions at time prevented water from reaching drains
Measures taken, or intended to be taken, to stop any emission	Redirected water to prevent overspill
Description of the failure or accident.	Drain pit pump failure

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	


	INITIALS	DATE
OK FOR PUBLIC REGISTER	EV	22/8/13
COPIED TO PUBLIC REGISTER	JB	EDem

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	High level alarm installed , to be monitored by security during routine patrol
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Lee Faulkner
Post	Facilities Manager
Signature	
Date	24/06/13

* authorised to sign on behalf of the operator