

## Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

### Part A

|                                |                                              |
|--------------------------------|----------------------------------------------|
| Permit Number                  | ZP3331LP                                     |
| Name of operator               | ENI Liverpool Bay Operating Company          |
| Location of Installation       | Talacre<br>Holywell<br>Flintshire<br>CH8 9RD |
| Time and date of the detection | 17:45 06/11/2015                             |

| (a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution |                                                                                                                                                                                                                                                                                            |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| To be notified within 24 hours of detection                                                                                                                                                        |                                                                                                                                                                                                                                                                                            |
| Date and time of the event                                                                                                                                                                         | 06/11/2015 17:45 to 08/11/2015 12:29                                                                                                                                                                                                                                                       |
| Reference or description of the location of the event                                                                                                                                              | Malfunction of NO <sub>x</sub> Analyser on the POA Thermal Oxidiser (TOX)                                                                                                                                                                                                                  |
| Description of where any release into the environment took place                                                                                                                                   | Release is via TOX stack (Emission point reference – A1)                                                                                                                                                                                                                                   |
| Substances(s) potentially released                                                                                                                                                                 | Nitrogen Oxide (NO <sub>x</sub> )                                                                                                                                                                                                                                                          |
| Best estimate of the quantity or rate of release of substances                                                                                                                                     | Hourly Average emission levels NO <sub>x</sub> – 35 mg/nm <sup>3</sup> .<br>This is below set environmental limits NO <sub>x</sub> – 120mg/nm <sup>3</sup> )                                                                                                                               |
| Measures taken, or intended to be taken, to stop any emission                                                                                                                                      | Monitored SRU / TGU process parameters. No excursions prior to instrument failure. CCR Operator monitoring plant operating conditions. Onsite technicians informed of failure.<br>SO <sub>2</sub> Emission levels 38 mg/nm <sup>3</sup> , remain within target of 190 mg/nm <sup>3</sup> , |
| Description of the failure or accident.                                                                                                                                                            | The analyser went into fault, reading negative values.                                                                                                                                                                                                                                     |


| <b>(b) Notification requirements for the breach of a limit</b>                      |   |
|-------------------------------------------------------------------------------------|---|
| <b>To be notified within 24 hours of detection unless otherwise specified below</b> |   |
| Emission point reference/ source                                                    | - |
| Parameter(s)                                                                        | - |
| Limit                                                                               | - |
| Measured value and uncertainty                                                      | - |
| Date and time of monitoring                                                         | - |
| Measures taken, or intended to be taken, to stop the emission                       | - |

| <b>Time periods for notification following detection of a breach of a limit</b> |                            |
|---------------------------------------------------------------------------------|----------------------------|
| <b>Parameter</b>                                                                | <b>Notification period</b> |
| -                                                                               |                            |
| -                                                                               |                            |
| -                                                                               |                            |

| <b>(c) Notification requirements for the detection of any significant adverse environmental effect</b> |   |
|--------------------------------------------------------------------------------------------------------|---|
| <b>To be notified within 24 hours of detection</b>                                                     |   |
| Description of where the effect on the environment was detected                                        | - |
| Substances(s) detected                                                                                 | - |
| Concentrations of substances detected                                                                  | - |
| Date of monitoring/sampling                                                                            | - |

## Part B - to be submitted as soon as practicable

|                                                                                                                                                        |                                                                                                                                                                                                                                                                                                                                   |
|--------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Any more accurate information on the matters for notification under Part A.                                                                            | Nox Analyser checked by site technician and confirmed the fault was due to a failure of the analyser lamp.                                                                                                                                                                                                                        |
| Measures taken, or intended to be taken, to prevent a recurrence of the incident                                                                       | <p>The analyser lamp was replaced with a spare lamp in stock and the analyser put back into service. The lamps are changed out at a shorter interim, compared to the manufacturer's recommendation to avoid this type of failure.</p> <p>The analyser has been monitored over last week and found to be working satisfactory.</p> |
| Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission | Not Applicable.                                                                                                                                                                                                                                                                                                                   |
| The dates of any unauthorised emissions from the installation in the preceding 24 months.                                                              | Not Applicable.                                                                                                                                                                                                                                                                                                                   |

|                  |                                                                                      |
|------------------|--------------------------------------------------------------------------------------|
| <b>Name*</b>     | Dhillip Sankoomar                                                                    |
| <b>Post</b>      | Plant Manager                                                                        |
| <b>Signature</b> |  |
| <b>Date</b>      | 13/11/2015                                                                           |

\* authorised to sign on behalf of Eni Liverpool Bay Operating Company Ltd.