

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	EPR/DP3934EW (formerly ZP3331LP)
Name of operator	ENI UK Ltd. Liverpool Bay Asset
Location of Installation	Talacre Holywell Flintshire CH8 9RD
Time and date of the detection	10:58 24/07/2018

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection	
Date and time of the event	N/A
Reference or description of the location of the event	N/A
Description of where any release into the environment took place	N/A
Substances(s) potentially released	N/A
Best estimate of the quantity or rate of release of substances	N/A
Measures taken, or intended to be taken, to stop any emission	N/A
Description of the failure or accident.	N/A

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	W1 on site plan in Schedule 2 of Permit, emission to Talacre New Drain.
Parameter(s)	Biochemical Oxygen Demand (BOD)
Limit	BOD – 15 mg/ml
Measured value and uncertainty	BOD – 18 mg/l, Uncertainty Unknown. Test undertake by UKAS


	Accredited Laboratory-Intertek.
Date and time of monitoring	BOD – 16 th July 2018 0930 to 17 th July 2018 1915
Measures taken, or intended to be taken, to stop the emission	Microtox Measurements were taken and passed prior to the discharge of the water to the outfall. Subsequent water discharges are being monitored.

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period
-	
-	
-	

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	-
Substances(s) detected	-
Concentrations of substances detected	-
Date of monitoring/sampling	-

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	-
Measures taken, or intended to be taken, to prevent a recurrence of the incident	-
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	-
The dates of any unauthorised emissions from the installation in the preceding 24 months.	-

Name*	Dhillip Sankoomar
Post	Plant Manager
Signature	
Date	27/07/2018

* authorised to sign on behalf of ENI UK Ltd. Liverpool Bay Asset