

Permit Reference Number: **EPR/SP3531SK**

Operator: **Tradebe (Gwent) Ltd**

Installation: **Gwent Waste Management Centre**

Form Number: **SC1**

Reporting of Scrubber Operation for the period from01/07/21.....to.....31/12/21.....

Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
SC1 ^[6]	pH	pH ≥ 8.5	Max 12.8 Min 9.1	BS 6068-2.50:1995, ISO 10523:1994.	06 July 21 06:45 06 Sept 21 06:25	ISO9001:2008 SGS	±0.05
SC2	pH	pH ≤ 5	2.5	BS 6068-2.50:1995, ISO 10523:1994.	06 Dec 21 06:25	ISO9001:2008 SGS	±0.05
SC3	pH	pH ≥ 10	13.3	BS 6068-2.50:1995, ISO 10523:1994.	10 Aug 21 07:00	ISO9001:2008 SGS	±0.05

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated

[6] The pH limit was changed from pH ≥ 10 to pH 8.5 – 9.5 on 19 May 2017 via an e mail following a review of the scrubber pH best practice.

Signed
(Authorised to sign as representative of the Operator)



Alex Morris.....

Date.....18/01/2022.....