

Releases to Air - LCPD/PPC Continuous Measurement

Operational Summary for the 3 months to 31/03/2014

Operator: E:ON UK

Site Location: Connah's Quay

Release Points: A1, A2, A3, A4

Permit/Variation Number: MP3337SH

Release Point	Pollutant	Month	ELV (mg/m3)	Max Daily Average	Calendar Monthly Mean	95% of validated hourly means
A1	NOx	21	75	-	-	-
A1	CO	Jan	30	-	-	-
A1	NOx	Feb	75	45.23	38.58	38.50
A1	CO	Feb	30	1.68	1.44	1.30
A1	NOx	Mar	75	45.88	39.67	46.10
A1	CO	Mar	30	1.43	1.17	1.70
A1	NOx	Annual	75			Due at end of year
A1	CO	Annual	30			Due at end of year
A2	NOx	Jan	75	-	-	-
A2	CO	Jan	30	-	-	-
A2	NOx	Feb	75	-	-	-
A2	CO	Feb	30	-	-	-
A2	NOx	Mar	75	-	-	-
A2	CO	Mar	30	-	-	-
A2	NOx	Annual	75			Due at end of year
A2	CO	Annual	30			Due at end of year
A3	NOx	Jan	75	26.96	25.58	26.20
A3	CO	Jan	30	1.52	1.41	1.30
A3	NOx	Feb	75	32.23	29.07	24.70



A3	CO	Feb	30	1.5	1.48	1.60
A3	NOx	Mar	75	30.75	30.75	29.50
A3	CO	Mar	30	1.38	1.38	1.20
A3	NOx	Annual	75			Due at end of year
A3	CO	Annual	30			Due at end of year
A4	NOx	Jan	75	21.27	20.89	20.80
A4	CO	Jan	30	5.1	3.13	1.10
A4	NOx	Feb	75	26.7	22.06	25.00
A4	CO	Feb	30	2.85	1.72	7.50
A4	NOx	Mar	75	26.66	24.24	26.60
A4	CO	Mar	30	2.90	1.41	1.70
A4	NOx	Annual	75			Due at end of year
A4	CO	Annual	30			Due at end of year

Notes - 1 Compliance with LCPD articles 4.1, 4.3 require measurement results for:

Nitrogen oxides (as NO₂) to demonstrate that:

- i) none of the validated daily averages exceeds the ELV
- ii) 95% of all validated hourly averages do not exceed 150% of the ELV

Signed.....
(Authorised to sign as a representative of operator)

Date.....

Air - 2 LCPD Continuous (01/12/06)