

24 APR 2014

LCPD REPORTING- Continuous measurement systems invalidations log

Release Point: A4

[illegible]

Signed.....

Date.....

Form: Air 3 – Continuous measurement invalidation log (01/12/06)

UNIONING RETURNS N. WALES

CHECKED V6 AUTHORISATION

1 FACING

OK FOR PUBLIC REGISTER

THE NEW YORK PUBLIC LIBRARY

INITIALS DATE

8K	30.6.14
JB	28.4.14
8K	30.6.14
JB	EDRM

RECEIVED

24 APR 2014

RELEASES TO AIR

LCPD REPORTING- Continuous measurement systems invalidations log

Operational

Operator: E.ON UK PLC

Location: Connah's Quay Power Station

Permit/Variation number:

Release Point: A1

Emissions to Air – Invalidation Log

Date	Period of invalidation (hours)	Cumulative invalidated days in year	Comments
31/03/2014	0	0	N/A

Signed.....

Date.....

Form: Air 3 – Continuous measurement invalidation log (01/12/06)

RECEIVED

24 APR 2014

RELEASES TO AIR
LCPD REPORTING- Continuous measurement systems invalidations log

Operational

Operator: E.ON UK PLC

Location: Connah's Quay Power Station

Permit/Variation number:

Release Point: A2

Emissions to Air – Invalidation Log

Date	Period of invalidation (hours)	Cumulative invalidated days in year	Comments
31/03/2014	0	0	N/A

Signed.....

Date.....

Form: Air 3 – Continuous measurement invalidation log (01/12/06)

RELEASES TO AIR
LCPD REPORTING- Continuous measurement systems invalidations log



Operational

Operator: E.ON UK PLC

Location: Connah's Quay Power Station

Permit/Variation number:

Release Point: A3

Emissions to Air – Invalidation Log

Date	Period of invalidation (hours)	Cumulative invalidated days in year	Comments
31/03/2014	0	0	N/A

Signed.....

Date.....

Reporting of emissions to air for the period from 01/01/2014 to 31/03/2014

Operator: E.ON UK

Site Location: Connahs Quay

Permit/Variation Number: MP3337SH

Release Points: A11, A12

Release Point	Substance / Parameter	ELV (mg/m ³)	Reference Period	Result (mg/m ³)
A11	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	95	10 min average	88
A12	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	95	10 min average	69.3*
A11	Carbon Monoxide	10	10 min average	8
A12	Carbon Monoxide	100	10 min average	68.3*
A11	Sulphur dioxide	9950	10 min average	118

*External monitoring completed by E.ON Engineering wk commencing 23rd December 2013

Signed on behalf of the Operator

Form Ref: Air - 1 / Connahs Quay PS (01/12/06)

