

Reporting of emissions to water (other than to sewer) for the period from 01/04/2013 to 30/06/2013

Operator: E.ON UK

Site Location: Connahs Quay

Permit/Variation Number: MP3337SH

Release Points: W1, W2



Release Point	Substance / Parameter	ELV	Reference Period	Result
W1	Flow	2.5m ³ /sec	Instantaneous	2.50
W1	Temperature	25°C	Instantaneous	23.3
W1	Temperature Difference April - October	13°C	Instantaneous	9.1
W1	Temperature Difference November - March	13°C	Instantaneous	
	95 percentile Maximum (deg C)	20°C		
W1	Salinity	60g/l	Instantaneous	55.0
W1	pH Maximum	9	Instantaneous	8.4

W1	pH Minimum	6	Instantaneous	6.5
W1	Total Residual Oxidant (TRO)	0.2mg/l	Instantaneous	0.03
W1	Oil and Grease	20mg/l	Instantaneous	15.6
W2	pH Maximum	9	Instantaneous	8.89
W2	pH Minimum	6	Instantaneous	6.9
W2	Oil and Grease	20mg/l	Instantaneous	<1

Signed on behalf of the Operator