

Releases to Air - LCPD/PPC Continuous Measurement

Operational Summary for the 3 months to 30/06/2013

Operator: E.ON UK

Site Location: Connah's Quay

Release Points: A1, A2, A3, A4

Permit/Variation Number: MP3337SH

Release Point	Pollutant	Month	ELV (mg/m3)	Max Daily Average	Calendar Monthly Mean	95% of validated hourly means
A1	NOx	Apr	75	29.36	27.87	31.6
A1	CO	Apr	30	1.67	1.58	1.6
A1	NOx	May	75	33.49	29.72	36.7
A1	CO	May	30	1.65	1.53	1.7
A1	NOx	Jun	75	38.41	33.25	36.8
A1	CO	Jun	30	1.81	1.43	1.6
A1	NOx	Annual	75			Due at end of year
A1	CO	Annual	30			Due at end of year
A2	NOx	Apr	75	40.86	40.18	40.7
A2	CO	Apr	30	1.87	1.65	1.5
A2	NOx	May	75	43.95	39.33	42.7
A2	CO	May	30	2.31	1.68	2
A2	NOx	Jun	75	60.31	48.62	53.6
A2	CO	Jun	30	2.32	1.5	2.4
A2	NOx	Annual	75			Due at end of year
A2	CO	Annual	30			Due at end of year
A3	NOx	Apr	75	25.33	25.33	24.8
A3	CO	Apr	30	1.03	1.03	1.1
A3	NOx	May	75	28.18	25.07	28.5
A3	CO	May	30	1.3	1.23	1.4
A3	NOx	Jun	75	26.77	23.17	27.6
A3	CO	Jun	30	1.43	1.16	1.3
A3	NOx	Annual	75			Due at end of year
A3	CO	Annual	30			Due at end of year



A4	NOx	Apr	75	42.99	32.52	43.8
A4	CO	Apr	30	1.74	1.5	3.2
A4	NOx	May	75	40.16	34.91	30.5
A4	CO	May	30	1.62	1.46	1.5
A4	NOx	Jun	75	-	-	-
A4	CO	Jun	30	-	-	-
A4	NOx	Annual	75			Due at end of year
A4	CO	Annual	30			Due at end of year

Notes - 1 Compliance with LCPD articles 4.1, 4.3 require measurement results for:

Nitrogen oxides (as NO₂) to demonstrate that:

- i) none of the validated daily averages exceeds the ELV
- ii) 95% of all validated hourly averages do not exceed 150% of the ELV

Signed.....

Date.....

(Authorised to sign as a representative of operator)

Air - 2 LCPD Continuous (01/12/06)