



Permit Reference Number: AP3833HZ

Operator: 2 Sisters Food Group .

Installation: Llangefni

Form Number: S2

Reporting of Emissions to Sewer for the period from 01.04.15 to 30.06.15

Emission Point	Substance / Parameter	Emission Limit Value/ $\mu\text{g l}^{-1}$	Emission Level / $\mu\text{g l}^{-1}$	Annual Mass Limit /g	Annual Mass Release /g
S1	Mercury	3	0	30	0

Emission Point	Substance / Parameter	Maximum /mg l ⁻¹		Minimum /mg l ⁻¹		Average /mg l ⁻¹	Number of Results
		Value	Date	Value	Date		
S1	Chemical Oxygen Demand (COD)	987	04.06.15	606	19.06.15	737.3	176

Emission Point	Average Effluent Flow $\text{m}^3 \text{day}^{-1}$
S1	1116.84

Operator's Comments: Effluent Plant running within Discharge Consent levels

Signed
(authorised to sign as representative of the Operator)

Date 11.11.15.....

AP3833HZ