



Permit Reference Number: SP3430RL

Operator: 2 Sisters Food Group.

Installation: Llangefni

Form Number: S2

Reporting of Emissions to Sewer for the period from 01.10.15 to 31.12.15

Emission Point	Substance / Parameter	Emission Limit Value/ $\mu\text{g l}^{-1}$	Emission Level $\mu\text{g l}^{-1}$	Annual Mass Limit /g	Annual Mass Release /g
S1	Mercury	3	0	30	0

Emission Point	Substance / Parameter	Maximum / mg l^{-1}		Minimum / mg l^{-1}		Average / mg l^{-1}	Number of Results
		Value	Date	Value	Date		
S1	Chemical Oxygen Demand (COD)	967	01.12.15	292	09.11.15	617.2	156

Emission Point	Average Effluent Flow $\text{m}^3 \text{ day}^{-1}$
S1	942.69

Operator's Comments: Effluent Plant running within Discharge Consent levels

Signed
(authorised to sign as representative of the Operator)

Date11.02.16

SP3430RL