



Permit SP3430RL

FUGITIVE EMISSION REPORT 2015 – 2 SISTERS FOOD GROUP , LLANGEFNI SITE

Fugitive Emissions from the site during 2015

Response:-

Incident Reports

The following Odour Complaints A&B Reports were submitted :-

25.06.15
02.10.15
07.10.15
08.10.15

The following Blood spillage A&B Report was submitted :-

12.10.15 – No off site emission took place.

General Fugitive Emissions

The Sludge tank scrubber ,Blood scrubber and Parsons Scrubber are bunded.

The two scrubbers are maintained by external contractors as per our Critical Maintenance Schedule.

All IBC chemical containers are stored on IBC spill bunds.

The Intake yard drains are all returned to the DAF Plant for cleaning and then passed to sewer via a discharge consent.

The DAF Plant is maintained by M&S Water Services Ltd.

All bulk deliveries to the DAF Plant are overseen by the DAF Plant operators as per the operational procedures.

All ABP waste is removed from site daily in order to prevent any odour emissions. The offal house is covered preventing fugitive emissions from vehicles , whilst being loaded.

Ammonia levels in our final surface water drain W1 are checked internally daily and weekly by M&S Water Services Ltd.

A full drain survey was completed in 3/4th quarter 2015 as per the Reg36 notice dated 24.07.15 and remedial work including the installation of an Aquasentry valve and a new NS35 full retention interceptor will be completed by the 2nd quarter 2016 .

In the event of a major spillage the Site Emergency Plan is activated, which includes the use of spillkits by our trained staff.



Permit SP3430RL

Corrective Action :-

- a) Completion of the REG36 notice dated 03.03.16 – ongoing
- b) Regular monthly monitoring and inspection of drainage & bunds - ongoing