RECEIVED
05 DEC 2013

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	SP 30 30 LZ
Name of operator	IPSEN BIOPHARM LTD
Location of Installation	WREXHAM INDUSTRIAL ESTATE
Time and date of the detection	03 Dec 2013

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	03 Dec 2013 04:00hrs
Reference or description of the location of the event	Biofill Plant room
Description of where any release into the environment took place	Discharge pipe on the side of a compressor
Substances(s) potentially released	R507
Best estimate of the quantity or rate of release of substances	7.5 K
Measures taken, or intended to be taken, to stop any emission	Pipework tightened and pressure tested immediately - increase level of leak detection on the machine room.
Description of the failure or accident.	The union on the discharge pipe on the side of the compressor had come loose

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	*
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

* Release of approximately 7.5 kg of R507 to atmosphere.

	INITIALS	DATE
OK FOR PUBLIC REGISTER	EV	9/12/13
COPIED TO PUBLIC REGISTER	JB	EDRM