RECEIVED
27 JUN 2014

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	SP3030LZ
Name of operator	Ipsen Biopharm Ltd
Location of Installation	Wrexham Industrial Estate
Time and date of the detection	26/06/2014 - 16:00 pm

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	3-4 hrs previous to date of detection
Reference or description of the location of the event	Unit 8 - Small air-con office unit
Description of where any release into the environment took place	South elevation of unit 8 - direct to atmosphere
Substances(s) potentially released	R410 a
Best estimate of the quantity or rate of release of substances	0.64 kg.
Measures taken, or intended to be taken, to stop any emission	Not detected at time of release.
Description of the failure or accident.	Whilst replacing store cladding panels - supply pipework was disturbed that resulted in a small fracture to a weld

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	Not applicable
Parameter(s)	—
Limit	—
Measured value and uncertainty	—
Date and time of monitoring	—
Measures taken, or intended to be taken, to stop the emission	—

	INITIALS	DATE
OK FOR PUBLIC REGISTER	EV	2/7/14
COPIED TO PUBLIC REGISTER	JB	EDRM

Time periods for notification following detection of a breach of a limit	
Parameter	**Notification period**

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	None detected
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

Name*	S Williams
Post	EHS Manager.
Signature	S Williams
Date	27/06/2014

* authorised to sign on behalf of Ipsen Biopharm Ltd.