



Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	PP3834CB
Name of Operator	Morgan Technical Ceramics Limited
Location of Installation	Vauxhall Industrial Estate, Ruabon, Wrexham, LL14 6HY
Location of the emission	S1 - To Sewer
Time and date of the emission	05/09/2013 @ 11.05

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Lead	Water	Water sample taken showing a result of 3.4mg/l against limit of 2mg/l	05/09/2013 @ 11.05

Description of the failure or accident	We have just received our latest water analysis report from Welsh Water, re: trade effluent consent. The breakdown analysis has detected a breach of lead content. We are currently employing a third party supplier to manage the system on a daily basis (Hydro Industries), to optimise process settings for our relatively new ETP in order to confirm its safe and correct operation.
Measures taken, or intended to be taken, to stop the emission	Meet with Hydro Industries to discuss result, possible causes & generate action plan to address issue & feedback to Natural Resources Wales by 30 th September 2013

Name*	Kathleen Coward
Post	EHS Compliance Manager
Signature	
Date	19 th September 2013

* authorised to sign on behalf of Morgan Technical Ceramics Limited

	INITIALS	DATE
OK FOR PUBLIC REGISTER	<input checked="" type="checkbox"/>	20/9/13
COPIED TO PUBLIC REGISTER	JB	EDM