

RECEIVED

28 JUN 2013

HAF076v3 – 18.06.13

Schedule 6 - Notification

Part A

Permit Number	PP3139GB
Name of Operator	Cory Environmental (Central) Limited
Location of Installation	Bangor Road Johnstown Wrexham LL14 6ET
Time and date of the detection	May 2013

b) Notification requirements for breach of a limit

To be notified within 24 hours of detection unless otherwise specified

Emission point reference/source	ID	Date	Leachate head (m)	Transducer Reading (m)	Comments
Parameter(s)	LC1	01/05/2013	14.60	14.28	Perched level
Limit		08/05/2013	10.86	12.36	Perched level
Measured value and uncertainty		14/05/2013	11.47	12.02	Perched level
		21/05/2013	4.76	6.37	2 nd electric pump installed
Date and time of monitoring		29/05/2013	4.98	3.20	Perched level
	LC2	01/05/2013	1.46	5.44	New pump fitted
		08/05/2013	0	Cable come out	
		14/05/2013	0	No readout	
		21/05/2013	Dip meter stuck		
29/05/2013		2.56	Disconnected		
Measures taken, or intended to be taken, to stop the emission	See below.				

Part B

Any more accurate information on the matters for notification under Part A.	<p>The levels in LC1 have fluctuated between 14.60m and 4.76m during May. A second electric pump has been installed to pump incoming perched leachate which is having a positive effect. Leachate continues to be extracted from the main sump in the side wall riser of Cell1 but quantities removed are low, which proves that the overall level in Cell 1 does not reflect those recorded by the monitoring chamber.</p> <p>The levels in LC2 have fluctuated between 2.56m and being dry, which shows a significant improvement within Cell 2.</p> <p>LC3 has been consistently below compliant levels throughout this reporting period.</p> <p>During May 2636 m3 of leachate was removed from site for treatment.</p>
Measures taken, or intended to be taken, to prevent a recurrence of the incident	See above.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	None – no pollution or harm has occurred.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

OK FOR PUBLIC REGISTER

COPIED TO PUBLIC REGISTER

INITIALS

DATE

JB

24/7/13

JB

EDem

Name*	Ian Craven
Post	NW Area Manager
Date	18/06/13

* authorised to sign on behalf of Cory Environmental (Central) Ltd

DATE	INITIALS	OK FOR PUBLIC REGISTRY
DATE	INITIALS	COPIED TO PUBLIC REGISTRY