

Schedule 6 - Notification

Part A

Permit Number	BS8621
Name of Operator	Cory Environmental (Central) Limited
Location of Installation	Bangor Road Johnstown Wrexham LL14 6ET
Time and date of the detection	Date entered onto Cory database

b) Notification requirements for breach of a limit				
To be notified within 24 hours of detection unless otherwise specified				
Emission point reference/source				
Parameter(s)	Date	Sample Point	Conductivity (uS/cm)	Limit
Limit				
Measured value and uncertainty	18/03/2014	HAF SW1A	1180	1090
Date and time of monitoring				
Measures taken, or intended to be taken, to stop the emission	Please see below.			

Part B

Any more accurate information on the matters for notification under Part A.	Routine monitoring returned the elevated levels detailed above. All the other parameters remained within the SW limits set by the Permit. It is unusual to see conductivity as a permit limit as it is just a check on the total salts in solution and can be affected by a number of naturally occurring ions. Site note that the Canada geese have returned to this lagoon, with 3 pairs now breeding here. This may have some localised effect on water quality.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	N/a
The dates of any unauthorised emissions from the installation in the preceding 24 months.	See previous Schedule 6 reports.

Name*	Anna Hamilton
Post	Environmental Data Assistant
Date	07/04/2014

* authorised to sign on behalf of Cory Environmental (Central) Ltd

OK FOR PUBLIC REGISTER	DETAILS	DATE
	<i>[Signature]</i>	22/4/14
COPIED TO PUBLIC REGISTER	JB	EDRM