

RECEIVED

04 OCT 2013

HAF079 – 03.10.2013

Schedule 6 - Notification

Part A

Permit Number	BS8621
Name of Operator	Cory Environmental (Central) Limited
Location of Installation	Bangor Road Johnstown Wrexham LL14 6ET
Time and date of the detection	19 th September 2013 @ 15:00hrs (approx.)

b) Notification requirements for breach of a limit	
To be notified within 24 hours of detection unless otherwise specified	
Emission point reference/source:	Engine 1 (CAT 3516) Exhaust Stack
Parameter(s):	Total VOCs (as Carbon)
Limit:	Limit with allowable tolerance is: 1000 mg/m3 +/- 82 mg/m3
Measured value and uncertainty	Approximately 1739.9 mg/m3 +/- 82mg/m3emitted, this will need confirmation when the full report is issued.
Date and time of monitoring:	19 th September 2013 @ 15:00 hrs
Measures taken, or intended to be taken, to stop the emission	The engine will remain operational and will undergo investigation and repair shortly. Discussions and possible corrective actions shall be held with the engine manufacturer. The engines will be retested on completion of the works.

Part B

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	See previous Schedule 6 reports.

Name*	Steve Conry
Post	Head of LFG & Biogas
Date	03/10/2013

* authorised to sign on behalf of Cory Environmental (Central) Ltd

OK FOR PUBLIC REGISTER	INITIALS /e	DATE 7/10/13
COPIED TO PUBLIC REGISTER	JB	EORM