

Mr A Black
E.ON UK plc
Connah's Quay Power Station
Kelsterton Road,
Connah 's Quay,
Flintshire,
CH5 4BP

3 April 2013

Dear Andy,

**THE ENVIRONMENTAL PERMITTING (ENGLAND AND WALES)
REGULATIONS 2010, as amended.**


EPR Permit MP3337SH/V005 Pre-Operational condition 2

With respect to your submission MP3337SH/V005 Pre-Operational condition 2 of the 13 March 2013, Natural Resources Wales considers satisfactory the monitoring standards and methods proposed for the parameters listed in Table S4.2 (Point Source Emissions to Water at emission point W1) subject to the following submissions having been received (by 26 April 2013):

- 1.6 the method of measurement and calibration standards for the Steptech instruments oil in water monitoring system,
- 2.1 details of the salinity, free chlorine, turbidity and oil and grease back-up methods,
- 3.2 clarity on what the limit of detection for oil and grease 0 or 1 means? We believe this instrument works by detecting a surface film of oil, so what does this mean in terms of quantity?, and
- the audit methodology employed to assess the competence of the variety of external companies that carry out the monitoring.

The overall monitoring approach including the above submissions will be subject to a detailed OMA Water audit at a date to be confirmed (previous audit 15 March 2011).

Yours sincerely,



Paul Wright PPC
Team leader 01244 894545

	INITIALS	DATE
OK FOR PUBLIC REGISTER		3/4/13
COPIED TO PUBLIC REGISTER?	JB	EDM