

Notice of variation with introductory note

Environmental Permitting (England & Wales) Regulations 2010

E.ON UK PLC

Connah's Quay Power Station
Kelsterton Road
Connah's Quay
Deeside
Flintshire
CH5 4BP

Variation application number
EPR/MP3337H/V006

Permit number
EPR/MP3337SH

Connah's Quay Power Station

Permit number EPR/MP3337SH

Introductory note

This introductory note does not form a part of the notice

The following notice gives notice of the variation of an environmental permit.

This is an Environment Agency initiated variation to add an improvement condition to ensure that the regulated facility will comply with the Eels (England and Wales) Regulations 2009 (SI 2009/3344) and the Environment Agency's "Safe Passage for Eel" Regulatory Position Statement version 1 dated July 2012.

The schedules specify the changes made to the original permit.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit		
Description	Date	Response date / Comments
Application MP3337SH	Duly made 17/03/06	
Schedule 4 response (Additional Information)		26/10/06
Supplementary Information	20/11/06	20/11/06
Supplementary Information (email)	12/01/07	12/01/07
Permit MP3337SH determined	09/02/07	
Variation Application EA/EPR/MP3337SH/V002	Received 20/05/08 Duly made 05/06/08	
Schedule 5 request for further information	14/09/08	01/09/08
Standard Variation EA/EPR/MP3337SH/V002 issued	29/09/08	
Simple Standard variation application EPR/MP3337SH/V003	Received 20/11/08 Duly Made 05/12/08	
Supplementary information request	10/10/08	23/10/08
Supplementary information request	23/02/09	27/02/09
Variation EPR/MP3337SH/V003 issued	18/03/09	
Application for variation EPR/MP3337SH/V004	Duly made 09/11/10	
Variation EPR/MP3337SH/V004 issued	07/12/10	
Application for standard variation and additional information received EPR/MP3337SH/V005	Received 09/12/2011 Duly Made 27/01/2012	
1st Schedule 5 "Notice requiring further information" issued	29/02/2012	23/03/2012
Additional information received – Assessment of further Chlorite Decay Tests"		22/05/2012
2nd Schedule 5 "Notice requiring further information" issued	04/07/2012	24/07/2012
Additional information received - Dosing systems		09/08/2012
Additional information received - Commissioning Information and Emission Limit Values / Monitoring		17/10/2012
Additional information received – various responses		26/10/2012

Additional information received –
Timescales for staged
commissioning programme

19/11/2012

Standard Variation EPR/MP3337SH/V005 Issued	6/12/12	
Variation determined EPR/MP3337SH/V006	11/03/13	Environment Agency Initiated Variation, to incorporate Eel Regulations improvement condition.

Other Part A installation permits relating to this installation

Operator	Permit number	Date of issue
EON UK PLC, Westwood Way, Westwood Business Park, Coventry, CV4 8LG	24/67/10/124/E ver 1 (Licence to abstract water)	25/10/1996
EON UK PLC, Westwood Way, Westwood Business Park, Coventry, CV4 8LG	24/67/10/124/E ver 2 (Licence to abstract water)	03/01/2007
EON UK PLC, Connah's Quay Power Station, Kelsterton Road, Connah's Quay , Deeside, Flintshire, CH5 4BP	EU-ETS:GB-EA- ETCO2-0179 (Emissions trading scheme)	

End of introductory note

Notice of variation

Environmental Permitting (England and Wales) Regulations 2010

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 varies

Permit number
EPR/MP3337SH

issued to:
E.ON UK PLC (“the operator”)

whose registered office is at

Westwood Way
Westwood Business Park
Coventry
CV4 8LG

company registration number **02366970**

to operate a regulated facility at

Kelsterton Road
Connah’s Quay
Deeside
Flintshire
CH5 4BP

to the extent set out in the schedules.

The notice shall take effect from 11/03/2013

Name	Date
A.J. Nixon	11 March 2013

Authorised on behalf of the Environment Agency

Schedule 1 – conditions to be deleted

None

Schedule 2 – conditions to be amended

None

Schedule 3 – conditions to be added

The following condition is added following an Environment Agency initiated variation

Improvement condition IC22 is added to Table S1.3

Table S1.3 Improvement programme requirements

Reference	Requirement	Date
IC22	<p>The Operator shall undertake a review of the existing screening measures at the intakes and outfalls which provide and discharge water to and from the Installation. The review shall be undertaken with reference to the Eels (England and Wales) Regulations 2009 (SI 2009/3344) and the Environment Agency "Safe Passage of Eel" Regulatory Position Statement version 1 dated July 2012.</p> <p>The Operator shall submit details of the arrangement suitable to meet the requirements for the safe passage of eels [of the Eels (England and Wales) Regulations 2009 (SI 2009/3344)] by either:-</p> <ul style="list-style-type: none">• Providing a written proposal for the installation of an eel screen.• Providing a written proposal to the modification of existing screening arrangements.• Providing a written response with an explanation and description of how the existing screening arrangements can be regarded to meet the requirements for the safe passage of eels [of SI 2009/3344] either without change or with mitigation measures.• Providing a written response setting out a case for an exemption <p>In all cases, the proposal shall be submitted in writing for the approval of the Environment Agency. Where appropriate, each proposal shall contain an assessment of alternative options considered including impacts on other fish species and an explanation of why the proposed option has been chosen.</p> <p>Where installation of eel screen; modification of existing arrangements; or mitigation measures are proposed, the submission shall contain relevant timescales for installation in accordance with the Safe Passage of Eel Regulatory Position Statement version 1 dated July 2012.</p> <p>The proposals shall be implemented in accordance with the Environment Agency's written approval.</p>	30 September 2013