

Notice of request for more information

Environmental Permitting (England and Wales)
Regulations 2010

Notice requiring further information

To: Company Secretary
Uniper UK Limited
Westwood Way
Westwood Business Park
Coventry
CV4 8LG

Application number: PAN-000485

Natural Resources Wales, in exercise of its powers under paragraph 4 of Part 1 of Schedule 5 of the above Regulations, requires you to provide the information detailed in the attached schedule. The information is required in order to determine your application for a permit, dated 12th July 2016. The information requested should be sent to the following address by 4th November 2016.

This notice has been sent to Mr Andy Black.

Information should be sent to:

Victoria Seller
Permitting Service
Natural Resources Wales
Cambria House
29 Newport Road
Cardiff
CF24 0TP

Name	Date
	2 nd November 2016

Victoria Seller, Senior Permitting Officer (Regulated Industry)
Authorised on behalf of Natural Resources Wales

Ffôn/Tel 03000 654588
Ebost/Email Victoria.seller@cyfoethnaturiolcymru.gov.uk
Victoria.seller@naturalresourceswales.gov.uk

Schedule

Noise Impact Assessment

With reference to the document 'Connah's Quay Power Station: impact assessment of outlet attenuator removal on U3 and U4 cooling towers (version 2, September 2016)', please provide the following pieces of information:

1. In relation to the sound power levels used for the Unit 3 and 4 cooling towers, please provide details of how these levels were derived, including the location and distance from the source that measurements were taken; and
2. In relation to the sound pressure levels given in Table 3, please clarify and justify whether or not the cooling tower sound pressure levels have been entered as sound power levels per unit area in the modelling; and
3. In relation to the selection of sensitive receptors, please justify the omission of Kelsterton Hall as a sensitive receptor, as this property appears to have line of sight to the cooling towers.

END OF SCHEDULE