

Permit Number: EA/EPR/BW99999/G/V003 Operator: Kronospan Ltd

Facility: Chirk Particle Board Factory Form Number: Water1 / 040209

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2017 to 31/03/2017

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	8.5 mg/l	As Permit	25/03/2017	0.011
W1	Suspended Solids	100mg/l	97 mg/l	As Permit	24/03/2017	0.208
W1	pH	6 – 9	6.24 – 7.78	As Permit	10/02/2017 – 01/01/2017	0.004
W1	Ammonia	5 mg/l	4.91 mg/l	As Permit	10/03/2017	0.006
W1	Oil and Grease	15mg/l	12.7 mg/l	As Permit	23/03/2017	0.007
W1	Formaldehyde	2 mg/l	1.90 mg/l	As Permit	26/02/2017	0.003
W1	Discharge Volume	N/A	83899 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  Chelsea Barber Date 10/04/2017
(Authorised to sign as representative of Operator)

Corrections have been made as per condition 3.1.4

Permit Number:	EA/EPR/BW9999IGNV003	Operator:	Kronospan Ltd
Facility:	Chirk Particle Board Factory	Form Number:	FPET1 / 040209

Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/01/2017 to 31/03/2017

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
E1	pH	6 – 9	6.78	As Permit	02/02/2017	0.018
E1	Oil and Grease	15mg/l	0.4 mg/l	As Permit	02/02/2017	0.054
E1	Formaldehyde	1mg/l	0.88 mg/l	As Permit	02/02/2017	0.006
E1	Discharge Volume	N/A	38.6 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed 	Date <u>10/04/2017</u>
(Authorised to sign as representative of Operator)	

Corrections have been made as per condition 3.1