


Permit Number: EAVEPR/BW9999IG/V003 Operator: Kronospan Ltd

Facility: Chirk Particle Board Factory Form Number: Water1 / 040209

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2016 to 31/03/2016

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	4.54 mg/l	As Permit	05/01/2016	0.011
W1	Suspended Solids	100mg/l	98 mg/l	As Permit	07/01/2016	0.208
W1	pH	6 – 9	6.30 – 7.80	As Permit	14/01/2016 – 24/01/2016	0.004
W1	Ammonia	5 mg/l	4.70 mg/l	As Permit	07/02/2016	0.006
W1 W1	Oil and Grease	15mg/l	4.80 mg/l	As Permit	07/02/2016	0.007
W1	Formaldehyde	2 mg/l	1.90 mg/l	As Permit	06/01/2016	0.003
W1	Discharge Volume	N/A	126,089 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  K. Baise Date 13/05/2016
(Authorised to sign as representative of Operator)

Corrections have been made as per condition 3.1.4