

Permit Number: EA/EPR/BW99991G/M005

Operator:

Kronospan Ltd


Facility: Chirk Particle Board Factory

Form Number: FPET1 / 040209

Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/04/2013 to 30/06/2013

Emission Point		Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method	Sample Date	Uncertainty
E1		pH	6 – 9	6.11-7.6	As Permit	08/05/2013-05/04/2013	0.018
E1		Oil and Grease	15mg/l	0.0 mg/l	As Permit	15/04/2013	0.054
E1		Formaldehyde	1mg/l	0.98 mg/l	As Permit	15/05/2013	0.006
E1		Discharge Volume	N/A	283 m3	As Permit	N/A	NA

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  (Authorised to sign as representative of Operator)

Date.....10/07/2013.....

Corrections have been made as per condition 3.1

