

Permit Number: EA/EPR/BW9999IG/V003

Operator: Kronospan Ltd


Facility: Chirk Particle Board Factory

Form Number: Water1 / 040209

Reporting of emissions to water (other than to sewer) and land for the period from 01/07/2015 to 30/09/2015

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	7.3 mg/l	As Permit	09/08/2015	0.011
W1	Suspended Solids	100mg/l	71 mg/l	As Permit	15/09/2015	0.208
W1	pH	6 – 9	6.29 – 7.83	As Permit	07/09/2015 – 28/07/2015	0.004
W1	Ammonia	5 mg/l	4.66 mg/l	As Permit	10/09/2015	0.006
W1 W1	Oil and Grease	15mg/l	10.3 mg/l	As Permit	06/08/2015	0.007
W1	Formaldehyde	2 mg/l	1.71 mg/l	As Permit	15/07/2015	0.003
W1	Discharge Volume	N/A	49957 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  K. Smeets Date 06/10/2015.
(Authorised to sign as representative of Operator)

Corrections have been made as per condition 3.1.4

Permit Number: EA/EPR/BW9999IG/V003

Operator: Kronospan Ltd


Facility: Chirk Particle Board Factory

Form Number: FPET1 / 040209

Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/07/2015 to 30/09/2015

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
E1	pH	6 – 9	NO DICHARGE FROM THE EFFLUENT TANK HAS OCCURRED BETWEEN THE REPORTING PERIOD 01/07/2015-30/09/2015			
E1	Oil and Grease	15mg/l				
E1	Formaldehyde	1mg/l				
E1	Discharge Volume	N/A				

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  Date 06/10/2015

(Authorised to sign as representative of Operator)