



Permit Number: EA/EPR/BW9999IG/V003 Operator: Kronospan Ltd
Facility: Chirk Particle Board Factory Form Number: FPET1 / 040209

Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/01/2014 to 31/03/2014

Emission Point	Emission		Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
	Substance / Parameter	Limit Value				
E1	pH	6 – 9	6.07 – 6.34	As Permit	17/02/2014 – 07/01/2014	0.018
E1	Oil and Grease	15mg/l	12.9 mg/l	As Permit	08/02/2014	0.054
E1	Formaldehyde	1mg/l	0.62 mg/l	As Permit	02/03/2014	0.006
E1	Discharge Volume	N/A	274.2 m ³	As Permit	N/A	NA

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed RETH BAKER Date 30/04/2014
(Authorised to sign as representative of Operator)

RETURNING RETURNS N. WALSH

CHECKED V6 AUTHORISATION	INITIALS	DATE
OK FOR PUBLIC REGISTER	JB	15.14
	JB	15.14
	JB	15.14
	JB	EDAM

Corrections have been made as per condition 3.1

Permit Number: EA/EPR/BW9999IG/V003

Operator:

Kronospan Ltd

Facility: Chirk Particle Board Factory

Form Number:

Water1 / 040209

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2014 to 31/03/2014

Emission Point	Substance / Parameter	Emission		Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
		Limit Value					
W1	BOD	9.5 mg/l		5.3 mg/l	As Permit	18/01/2014	0.011
W1	Suspended Solids	100mg/l		90.5 mg/l	As Permit	06/02/2014	0.208
W1	pH	6 – 9		6.04 – 7.94	As Permit	25/03/2014 – 01/01/2014	0.004
W1	Ammonia	3.5 mg/l		4.87 mg/l	As Permit	25/02/2014	0.006
W1 W1	Oil and Grease	15mg/l		14.8 mg/l	As Permit	23/03/2014	0.007
W1	Formaldehyde	1.5 mg/l		1.82 mg/l	As Permit	09/02/2014	0.003
W1	Discharge Volume	N/A		139365 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  KEITH BAKER
(Authorised to sign as representative of Operator)

Date 30/04/2014

Corrections have been made as per condition 3.1.4