

Permit Number: EAVEPR/BW99991/GM005

Operator: Kronospan Ltd

Facility: Chilk Particle Board Factory

Form Number: FPET1 / 040209



Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/07/2013 to 30/09/2013

Emission Point	Substance / Parameter	Emission Limit Value	Result (1)	Test Method	Sample Date	Uncertainty
E1	pH	6 - 9	6.12-6.63	As Permit	26/07/2013-18/08/2013	0.018
E1	Oil and Grease	15mg/l	0.0 mg/l	As Permit	01/07/2013	0.054
E1	Formaldehyde	1mg/l	0.78 mg/l	As Permit	20/09/2013	0.006
E1	Discharge Volume	N/A	242 m3	As Permit	N/A	NA

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

Signed: *[Signature]*
(Authorised to sign as representative of Operator)

Date: 18/10/2013

Corrections have been made as per condition 3.1

QUANTUMS RETURNS N. WA 1-3

CHECKED BY AUTHORITY

TRIP CODE

ORIGINATOR'S SIGNATURE

QUANTUMS DATE

<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	22/10/13
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	21/10/13
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	22/10/13
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	ED/21/13

Permit Number: EA/EPR/BW98991/GV005

Operator: Kronospan Ltd


Facility: Chirk Particle Board Factory

Form Number: Water1 / 040209

Reporting of emissions to water (other than to sewer) and land for the period from 01/07/2013 to 30/09/2013

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	9.4 mg/l	As Permit	28/07/2013	0.011
W1	Suspended Solids	100mg/l	62 mg/l	As Permit	09/07/2013	0.208
W1	pH	6 - 9	6.09 - 7.58	As Permit	11/07/2013 - 19/08/2013	0.004
W1	Ammonia	5 mg/l	4.57 mg/l	As Permit	05/08/2013	0.006
W1	Oil and Grease	15mg/l	12.4 mg/l	As Permit	05/07/2013	0.007
W1	Formaldehyde	2 mg/l	1.7 mg/l	As Permit	29/09/2013	0.003
W1	Discharge Volume	N/A	65176 m ³	As Permit	NA	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

Signed:  (Authorised to sign as representative of Operator)

Date: 18/10/2013

Corrections have been made as per condition 3.1.4