

Permit Number: EAEPR/BW99991G/M003

Operator:

Kronospan Ltd

Facility:

Chirk Particle Board Factory

Form Number:

FPET1 / 040209

**Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/04/2014 to 30/06/2014**

		Emission				
Emission Point	Substance / Parameter	Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
E1	pH	6 – 9	6.30 – 6.44	As Permit	02/04/2014 – 11/06/2014	0.018
E1	Oil and Grease	15mg/l	8.1 mg/l	As Permit	02/04/2014	0.054
E1	Formaldehyde	1mg/l	0.74 mg/l	As Permit	02/04/2014	0.006
E1	Discharge Volume	N/A	79.2 m³	As Permit	N/A	NA

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed 
(Authorised to sign as representative of Operator)

Date 07/07/2014

Corrections have been made as per condition 3.1

4. UK'S RETURNING N/A

CHECKED VS AUTHORIZATION

3/3/2014

OK FOR PUBLIC RELEASE

INITIALS DATE

 23-7-14 23-7-14 23-7-14

OK FOR PUBLIC RELEASE

 23-7-14

Permit Number:

EA/EPR/BW99991GN/003

Operator:

Kronospan Ltd

Facility:

Chirk Particle Board Factory

Form Number:

Water1 / 040209

Reporting of emissions to water (other than to sewer) and land for the period from 01/04/2014 to 30/06/2014

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	8.9 mg/l	As Permit	02/05/2014	0.011
W1	Suspended Solids	100mg/l	63.5 mg/l	As Permit	23/05/2014	0.208
W1	pH	6 – 9	6.04 – 7.90	As Permit	09/04/2014 – 05/04/2014	0.004
W1	Ammonia	3.5 mg/l	4.78 mg/l	As Permit	24/04/2014	0.006
W1	Oil and Grease	15mg/l	15.0 mg/l	As Permit	12/05/2014	0.007
W1	Formaldehyde	1.5 mg/l	1.77 mg/l	As Permit	08/06/2014	0.003
W1	Discharge Volume	N/A	69430 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed:


(Authorised to sign as representative of Operator)

Date 07/07/2014

Corrections have been made as per condition 3.1.4