

Kronospan Ltd

Operator:

EA/EPR/BW9999IG/V003

Permit Number:

Water1 / 040209

Form Number:

Chirk Particle Board Factory

Facility:

Reporting of emissions to water (other than to sewer) and land for the period from 01/04/2016 to 30/06/2016

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	2.1 mg/l	As Permit	13/04/2016	0.011
W1	Suspended Solids	100mg/l	93 mg/l	As Permit	14/06/2016	0.208
W1	pH	6 – 9	6.21 – 8.02	As Permit	05/04/2016 – 25/04/2016	0.004
W1	Ammonia	5 mg/l	4.72 mg/l	As Permit	02/04/2016	0.006
W1	Oil and Grease	15mg/l	12.0 mg/l	As Permit	17/06/2016	0.007
W1	Formaldehyde	2 mg/l	1.97 mg/l	As Permit	02/04/2016	0.003
W1	Discharge Volume	N/A	100.554 m ³	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed

(Authorised to sign as representative of Operator)

Date 07/07/2016


Corrections have been made as per condition 3.1.4

Permit Number: EA/EPR/BW9999IG/V003
 Facility: Chirk Particle Board Factory
 Operator: Kronospan Ltd
 Form Number: FPET1 / 040209

Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/04/2016 to 30/06/2016

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method	Sample Date	Uncertainty
E1	pH	6 – 9	NO DICHARGE FROM THE EFFLUENT TANK HAS OCCURRED BETWEEN THE REPORTING PERIOD 01/04/2016-30/06/2016			
E1	Oil and Grease	15mg/l				
E1	Formaldehyde	1mg/l				
E1	Discharge Volume	N/A				

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  _____
 (Authorised to sign as representative of Operator)
 Date 07/07/2016

Corrections have been made as per condition 3.1