


Permit Number: EA/EPR/BW99999IG/V003 Operator: Kronospan Ltd

Facility: Chirk Particle Board Factory Form Number: Water1 / 040209

**Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2015 to 31/03/2015**

Emission Point	Substance / Parameter	Emission Limit Value	Result <sup>(1)</sup>	Test Method	Sample Date	Uncertainty
W1	BOD	9.5 mg/l	8.1 mg/l	As Permit	18/01/2015	0.011
W1	Suspended Solids	100mg/l	90 mg/l	As Permit	03/02/2015	0.208
W1	pH	6 – 9	6.22 – 7.98	As Permit	15/01/2015 – 05/01/2015	0.004
W1	Ammonia	5 mg/l	4.97 mg/l	As Permit	05/01/2015	0.006
W1 W1	Oil and Grease	15mg/l	14.9 mg/l	As Permit	24/02/2015	0.007
W1	Formaldehyde	2 mg/l	1.72 mg/l	As Permit	24/01/2015	0.003
W1	Discharge Volume	N/A	75,848 m <sup>3</sup>	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  K Banger Date 10/04/2015  
(Authorised to sign as representative of Operator)

Corrections have been made as per condition 3.1.4


Permit Number: EA/EPR/BW9999IG/N/003 Operator: Kronospan Ltd

Facility: Chirk Particle Board Factory Form Number: FPET1 / 040209

## Reporting of emissions from the formaldehyde plant effluent tank for the period from 01/01/2015 to 31/03/2015

Emission Point	Substance / Parameter	Emission Limit Value	Result <sup>(1)</sup>	Test Method	Sample Date	Uncertainty
E1	pH	6 – 9	6.14 – 7.00	As Permit	26/03/2015 – 07/02/2015	0.018
E1	Oil and Grease	15mg/l	0.9 mg/l	As Permit	26/03/2015	0.054
E1	Formaldehyde	1mg/l	0.90 mg/l	As Permit	15/01/2015	0.006
E1	Discharge Volume	N/A	82 m <sup>3</sup>	As Permit	N/A	N/A

(1) The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Signed  Date 10/04/2015  
(Authorised to sign as representative of Operator)

Corrections have been made as per condition 3.1