

April 2022

Day	Downtime	Availability	Rationale
1	0	100.00%	
2	0	100.00%	
3	6.5	72.92%	
4	3.5	85.42%	RHS Grate Jam
5	0	100.00%	
6	0	100.00%	
7	0	100.00%	
8	0	100.00%	
9	0	100.00%	
10	0	100.00%	
11	0	100.00%	
12	0	100.00%	
13	0	100.00%	
14	0	100.00%	
15	0	100.00%	
16	0	100.00%	
17	0	100.00%	
18	1.5	93.75%	Boiler trip due to ID fan DP, restarted
19	0	100.00%	
20	0	100.00%	
21	0	100.00%	
22	0	100.00%	
23	0	100.00%	
24	0	100.00%	
25	0	100.00%	
26	0	100.00%	
27	16.5	31.25%	RHS Grate VSD Lost Profibus card. Card & cooling fan replaced and reinstated Profibus
28	6	75.00%	comms. Delayed due to BFWP breaker unable to reset.
29	0	100.00%	
30	0	100.00%	
Month	34	95.28%	