

Releases to Air

Release summary for Quarter 2

Year 2022

Operator: Vale Europe Ltd.,
Permit No. BL 4567

Location: Clydach SA6 5QR

| Parameter | | Release Point Number | Month 1 | Month 2 | Month 3 | Limit |
|---|---------------------------------|----------------------|---------|---------|---------|---------------------|
| Particulates mg/m ³ | Maximum Hourly Average in Month | A54a | - | - | - | 5 (monthly average) |
| | | A54b | 1.62 | 0.99 | 3.13 | 5 (monthly average) |
| | Monthly Mean | A54a | - | | | |
| | | A54b | 0.285 | 0.203 | 0.175 | |
| Nickel compounds expressed as Ni kg/month | | A54a | - | - | - | |
| | | A54b | 3.8 | 2.7 | 2.3 | |
| Bypass of abatement time hh:mm | | A54a | - | | | |
| | | A54b | - | 3.10 | | |
| CEM Availability % | | A54a | - | - | - | |
| | | A54b | 100 | 100 | 100 | |
| Flue switched to A54a or A54b? | | | N | N | N | |
| Date of Main Stack Flue switching. | | | - | - | - | |

Operator should strikethrough boxes not applicable due to release point not in service.

Date: As Per Email

Fiona Sharp
Sustainability Co-ordinator
– for Richard De Filippo Sustainability Supervisor
Signed on behalf of Vale Europe Limited.,

Form A1 dated 27/10/03

Email to: industryregulation.swales@cyfoethnaturiolcymru.gov.uk