


Permit Number: EPR/EP3830GHOperator: Liberty Steel UK Ltd

Facility: Liberty Steel NewportForm Number: WaterUsage1 / 15/08/2016

Reporting of Water Usage for the year 2021

Water Source	Usage (m ³ /year)	Specific Usage (m ³ /unit output)
Mains water	67,683	0.51 m ³ /mt
Site borehole	-	-
Grey Water	-	-
TOTAL WATER USAGE		

Operator's comments:
Unable to utilise grey water supply via Welsh Water due to water cooled compressor issue. This was resolved in December 2021 where these units were replaced by air cooled units. This will result in an overall reduction in both mains and grey water in the coming year.



SignedDate: 17th February 2022