

Consent no	NRWWIA322
------------	-----------

## WATER INDUSTRY ACT 1991

### SECTION 165 / 166

### CONSENT TO DISCHARGE

TO: Dwr Cymru Cyfyngedig  
Linea House  
Fortran Road  
St Mellons  
Cardiff  
CF3 0LT

The **NATURAL RESOURCES BODY FOR WALES** ("Natural Resources Wales") in pursuance of its powers under the Water Industry Act 1991 **HEREBY CONSENTS** to the making of a discharge as follows:

**Raw Water release, via the scour valve, from Beacon Reservoir to maintain supply to Cantref and Llwynonn Reservoirs**

**FROM:** CANTREF RESERVOIR, BRECON, LD3 8NL

**AT:** NATIONAL GRID REFERENCE SN 99692 15436

**TO:** TAF FAWR

**SUBJECT TO:** the conditions set out in the following schedule:

<b>Raw Water</b>	Schedule No. NRWWIA322
------------------	------------------------

This consent is issued on the 5<sup>th</sup> day of August 2022  
This consent takes effect on the 5<sup>th</sup> day of August 2022  
This consent shall cease to have effect on the 21<sup>st</sup> day of November 2022

**Signed: Melissa Broad**

<b>CONSENT NO:</b>	NRWWIA322
<b>SCHEDULE NO:</b>	NRWWIA322-01
<b>DATE ISSUED:</b>	5 <sup>th</sup> August 2022

## **CONDITIONS OF CONSENT TO DISCHARGE RAW WATER (“the Discharge”)**

### NATURE OF THE DISCHARGE

1. The Discharge shall consist solely of raw water.

### SOURCE OF THE DISCHARGE

2. The Discharge shall be derived from Cantref Reservoir.

### LOCATION OF DISCHARGE

3. The location of the Discharge shall be at NGR SN 99692 15436, marked ‘Washout Location’ on the site plan in Annex 1.

### SAMPLE POINT

4. A sample point shall be provided and maintained so that a representative sample of the Discharge may be obtained.

### VOLUME

5. The total daily volume of the Discharge shall not exceed 285,120 cubic metres.
6. The rate of the Discharge shall not exceed 3,300 litres per second.

### COMPOSITION

8. The consent holder shall take all necessary steps to secure that any water discharged by it under this consent is as free as may be reasonably practicable from —
  - (a) mud and silt;
  - (b) solid, polluting, offensive or injurious substances;  
and
  - (c) any substances prejudicial to fish or spawn, or to spawning beds or food of fish.

<b>CONSENT NO:</b>	NRWWIA322
<b>SCHEDULE NO:</b>	NRWWIA322-01
<b>DATE ISSUED:</b>	5 <sup>th</sup> August 2022

### SCOURING

9. The rate of discharge shall be controlled to prevent any significant scouring of the bed or bankside of the receiving water in line with Environmental Risk Assessment 150827\_ERA and Management System dated April 2015 and submitted as part of the application of consent and approved by NRW.

### FLOODING

10. The discharge shall not cause or significantly contribute to flooding in the downstream catchment.


### PERIOD OF DISCHARGE

11. The Discharge shall only be made between 5<sup>th</sup> August 2022 and the 21<sup>st</sup> day of November 2022.

<b>CONSENT NO:</b>	NRWWIA322
<b>DATE ISSUED:</b>	5 <sup>th</sup> August 2022

## ANNEX 1- PLAN No. NRWWIA322

**Figure 1 - Site location**



**Figure 2 - location map of site with washout position and location where flow enters river.**

