

## Schedule 1 - Notification of abnormal emissions

This page outlines the information that the Operator must provide to satisfy conditions 5.1.1 and 5.1.2 of this Permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

### Part A

Permit Number	AP3433ES
Name of Operator	2 Sisters Red Meat t/a St Merryn Foods
Location of Installation	Merthyr Tydfil
Location of the emission	W1
Time and date of the emission	April 2017

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Mineral oils and Hydrocarbons	Water	11.2mg/l	13/04/2017


Measures taken, or intended to be taken, to stop the emission	Evaluation and operation check, emptying and cleaning of interceptor
---	--

### Part B

Any more accurate information on the matters for notification under Part A.	Commission third party report. Review of emergency response and monitoring procedures
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Schedule evaluation, emptying, cleaning of interceptor.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	2 Sisters Red Meat Merthyr, contracted a third party to produce a report on the functionality of W1 Interceptor. The report identified internal damage thought to be caused by very high volumes of water flow through this system. The contractor was commissioned to undertake a repair, on further closer inspection at the time of the repair it became evident that the repair should only be considered as temporary, a detailed survey and proposal is being drawn up to replace this system.
The dates of any unauthorised emissions from the installation in the preceding 24 months.	30/03/17 – S1 Emission of Mineral oil and hydrocarbon 02/03/17 – W1 Emission of Mineral oil and hydrocarbon 06/06/16 – Refrigerant leak from crack pipe in system MT3 02/06/16 – W2 Emission hydrocarbon 10/12/15 – S1 Emission ph 15/10/15 – S1 Emission hydrocarbon

Permit and introductory note: the PPC Regulations  
Schedule 1 - Notification of abnormal emissions

---

Name*	Rob Havercombe
Post	Environmental Manager
Signature	
Date	28/7/2017

\* authorised to sign on behalf of 2 Sisters Red Meat Ltd