

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	ZP3334AQ
Name of operator	Slicker Recycling
Location of Installation	Newquay Road, Newport, NP19 4PL
Time and date of the detection	11:50 on Saturday 27th May 2017

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution

To be notified within 24 hours of detection	
Date and time of the event	11:50 on Saturday 27th May
Reference or description of the location of the event	Isolated fire at the bottom of the yard area after lightning struck packaged empty containers.
Description of where any release into the environment took place	No sewer release, Black smoke in to the air
Substances(s) potentially released	None
Best estimate of the quantity or rate of release of substances	In total, 10 pallets of waste were affected.
Measures taken, or intended to be taken, to stop any emission	The fire was quelled with water by the fire brigade, 10 minutes after deployment.
Description of the failure or accident.	Lightning strike hitting an IBC of rags which smouldered for a few hours and ignited when the wind picked up

(b) Notification requirements for the breach of a limit

To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	N/A
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	N/A
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	Incident report filed and held on site.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Review storage areas and quantities of wastes stored on site. Emergency systems worked, though better immediate contacts for the Newport site would reduce reaction times.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Interceptor cleaned out Auto sampler to be replaced Drench Shower has been replaced
The dates of any unauthorised emissions from the installation in the preceding 24 months.	N/A

Name*	Ade Pitman
Post	Site Manager 
Signature	
Date	7th June 2017

* authorised to sign on behalf of **Eco-Oil Ltd**