

**RELEASES TO AIR
QUARTERLY RETURN
MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS
OPERATING MODE:**

Operator: Dow Silicones UK Ltd
Location: Barry Cogeneration Plant
Permit/Variation Number: EPR/JP3632ZH/V004

Form: IED CON 2 (Gas Turbines)
Version/date: V.3.1 31 Dec 2015

Year: 2022	A1 / LCP 60					
	NOx (mg/m3)			CO (mg/m3)		
Month	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean
January	-	-		-	-	-
February	-	-		-	-	-
March	113.11	118.57		3.8	7.0	30.4
April						
May						
June						
July						
August						
September						
October						
November						
December						
Monthly ELV / Daily ELV (f)	75.	82.5		80.	80.	
Annual 95th Percentile (h)						
Annual Percentile ELV (g)						

NOTES:

(a) All data based on validated hourly average concentrations, excluding start-up and shut-down and periods of malfunction or breakdown of abatement equipment, at 15% O₂, dry, 273.15K, 101.325 kPa

(b) Annual percentiles are submitted with the final return (Quarter 4)

(c) Extend report to cover the required number of LCP on each site and repeat report for each separately regulated Operating Mode as required, e.g., Combined Cycle, Open Cycle, Supplementary firing, Auxiliary firing

(d) Averages determined at loads in the range 70% < Load ≤ 100% ISO base load and above


(e) Averages determined at loads in the range MSUL* < Load = 100% ISO base load and above (* For a 3 parameter approach, from the point of Start-Up to the point of Shut-down)

(f) Leave the Daily ELV blank if this is applied as a 95th percentile ELV within the Permit

(g) For each pollutant, report the Annual 95th percentile ELV for hourly averages in the first column and, if applicable, the Annual 95th percentile ELV for daily means in the second column

(h) For each pollutant, report the Annual 95th percentile of hourly averages in the first column and, if applicable, the Annual 95th percentile of daily means in the second column

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

21st April 2022

No confidence adjustment

**RELEASES TO AIR
QUARTERLY RETURN
MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS
OPERATING MODE:**

Operator: **Dow Silicones UK Ltd** Form: IED CON 2 (Gas Turbines)
Location: **Barry Cogeneration Plant** Version/date: **V.3.1 31 Dec 2015**
Permit/Variation Number: **EPR/JP3632ZH/V004**

Year: 2022	A2 / LCP60					
	NOx (mg/m3)			CO (mg/m3)		
Month	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean
January	-	-		-	-	
February	-	-		-	-	
March	53.75	53.75		7.1	7.1	
April						
May						
June						
July						
August						
September						
October						
November						
December						
Monthly ELV / Daily ELV (f)	100	110		100	110	
Annual 95th Percentile (h)						
Annual Percentile ELV (g)						

New permit limits from 1 July 2020

NOTES:

- (a) All data based on validated hourly average concentrations, excluding start-up and shut-down and periods of malfunction or breakdown of abatement equipment, at 15% O₂, dry, 273.15K, 101.325 kPa
- (b) Annual percentiles are submitted with the final return (Quarter 4)
- (c) Extend report to cover the required number of LCP on each site and repeat report for each separately regulated Operating Mode as required, e.g., Combined Cycle, Open Cycle, Supplementary firing, Auxiliary firing
- (d) Averages determined at loads in the range 70% < Load ≤ 100% ISO base load and above
- (e) Averages determined at loads in the range MSUL* < Load = 100% ISO base load and above (* For a 3 parameter approach, from the point of Start-Up to the point of Shut-down)
- (f) Leave the Daily ELV blank if this is applied as a 95th percentile ELV within the Permit
- (g) For each pollutant, report the Annual 95th percentile ELV for hourly averages in the first column and, if applicable, the Annual 95th percentile ELV for daily means in the second column
- (h) For each pollutant, report the Annual 95th percentile of hourly averages in the first column and, if applicable, the Annual 95th percentile of daily means in the second column

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

21st April 2022

No confidence adjustment

**RELEASES TO AIR
QUARTERLY RETURN
MONTHLY MEAN, MAXIMUM DAILY MEAN AND ANNUAL PERCENTILE CONCENTRATIONS
OPERATING MODE:**

Operator: Dow Silicones UK Ltd
Location: Barry Cogeneration Plant
Permit/Variation Number: EPR/JP3632ZH/V004

Form: IED CON 2 (Gas Turbines)

Version/date: V.3.1 31 Dec 2015

Year: 2022	A3 / LCP60					
	NOx (mg/m3)			CO (mg/m3)		
Month	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean	Monthly Mean	Max Daily Mean	Part Load Max Daily Mean
January	26.38	29.93		3.8	13.0	68.7
February	28.66	31.38		1.0	6.8	78.1
March	49.24	75.02		9.5	23.6	54.0
April						
May						
June						
July						
August						
September						
October						
November						
December						
Monthly ELV / Daily ELV (f)	75.	82.5		80.	80.	
Annual 95th Percentile (h)						
Annual Percentile ELV (g)						

New permit limits from 1 July 2020

NOTES:

(a) All data based on validated hourly average concentrations, excluding start-up and shut-down and periods of malfunction or breakdown of abatement equipment, at 15% O₂, dry, 273.15K, 101.325 kPa

(b) Annual percentiles are submitted with the final return (Quarter 4)

(c) Extend report to cover the required number of LCP on each site and repeat report for each separately regulated Operating Mode as required, e.g., Combined Cycle, Open Cycle, Supplementary firing, Auxiliary firing

(d) Averages determined at loads in the range 70% < Load ≤ 100% ISO base load and above

(e) Averages determined at loads in the range MSUL* < Load = 100% ISO base load and above (* For a 3 parameter approach, from the point of Start-Up to the point of Shut-down)

(f) Leave the Daily ELV blank if this is applied as a 95th percentile ELV within the Permit

(g) For each pollutant, report the Annual 95th percentile ELV for hourly averages in the first column and, if applicable, the Annual 95th percentile ELV for daily means in the second column

(h) For each pollutant, report the Annual 95th percentile of hourly averages in the first column and, if applicable, the Annual 95th percentile of daily means in the second column

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

21st April 2022

No confidence adjustment

RELEASES TO AIR
QUARTERLY RETURN
2022
Q1
CUMULATIVE ROLLING MALFUNCTION AND BREAKDOWN HOURS (12 MONTH PERIOD)(a), (b)
OPERATING MODE:
Operator:
DOW
Location:
Barry Cogeneration Plant
Permit/Variation Number:
EPR/JP3632ZH/V004
Form:
IED/LCPBREF BD1
Version/date:
V.3.1 31 Dec 2015

Year: 2022	A1 / LCP 60			
	NOx (mg/m3)		CO (mg/m3)	
Month	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)
January	-	-	-	-
February	-	-	-	-
March	-	-	-	-
April				
May				
June				
July				
August				
September				
October				
November				
December				
Annual total (hours)				
Annual cap (hours)	120.	120.	120.	120.

NOTES:

(a) Cumulative rolling malfunction and breakdown hours (12 month period) updated monthly


(b) Data Acquisition and Handling Systems without the capability to report Black Start hours separately may incorporate Black Start hours on this form provided that a

(c) Insert the relevant months for the preceding 12 month period, e.g., starting with March 2016

(d) Gas turbines with CO abatement only (columns may be deleted for other plant types)

(e) Plants with HCl abatement only (columns may be deleted for other plant types)

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

21st April 2022

No confidence adjustment

RELEASES TO AIR
QUARTERLY RETURN
2022
Q1
CUMULATIVE ROLLING MALFUNCTION AND BREAKDOWN HOURS (12 MONTH PERIOD)(a), (b)
OPERATING MODE:
Operator:
DOW
Location:
Barry Cogeneration Plant
Permit/Variation Number:
EPR/JP3632ZH/V004
Form:
IED/LCPBREF BD1
Version/date:
V.3.1 31 Dec 2015

Year: 2022	A2 / LCP 60			
	NOx (mg/m3)		CO (mg/m3)	
Month	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)
January	-	-	-	-
February	-	-	-	-
March	-	-	-	-
April				
May				
June				
July				
August				
September				
October				
November				
December				
Annual total (hours)				
Annual cap (hours)	120.	120.	120.	120.

NOTES:

(a) Cumulative rolling malfunction and breakdown hours (12 month period) updated monthly

(b) Data Acquisition and Handling Systems without the capability to report Black Start hours separately may incorporate Black Start hours on this form provided that a

(c) Insert the relevant months for the preceding 12 month period, e.g., starting with March 2016

(d) Gas turbines with CO abatement only (columns may be deleted for other plant types)

(e) Plants with HCl abatement only (columns may be deleted for other plant types)

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

21st April 2022

No confidence adjustment

RELEASES TO AIR
QUARTERLY RETURN
2022
Q1
CUMULATIVE ROLLING MALFUNCTION AND BREAKDOWN HOURS (12 MONTH PERIOD)(a), (b)
OPERATING MODE:
Operator:
DOW
Location:
Barry Cogeneration Plant
Permit/Variation Number:
EPR/JP3632ZH/V004
Form:
IED/LCPBREF BD1
Version/date:
V.3.1 31 Dec 2015

Year: 2022	A3 / LCP 60			
	NOx (mg/m3)		CO (mg/m3)	
Month	Malfunction (hours)	Breakdown (hours)	Malfunction (hours)	Breakdown (hours)
January	-	-	-	-
February	-	-	-	-
March	-	-	-	-
April				
May				
June				
July				
August				
September				
October				
November				
December				
Annual total (hours)				
Annual cap (hours)	120.	120.	120.	120.

NOTES:

(a) Cumulative rolling malfunction and breakdown hours (12 month period) updated monthly


(b) Data Acquisition and Handling Systems without the capability to report Black Start hours separately may incorporate Black Start hours on this form provided that a

(c) Insert the relevant months for the preceding 12 month period, e.g., starting with March 2016

(d) Gas turbines with CO abatement only (columns may be deleted for other plant types)

(e) Plants with HCl abatement only (columns may be deleted for other plant types)

Signed on behalf of the Operator by:



Judith Sartor, Environmental Specialist

Date of return:

21st April 2022

No confidence adjustment