

**Permit Number: EPR/BL3986ID**

**Operator: Tarmac Cement and Lime Ltd**

**Installation: Aberthaw Works**

**Form number: Air 10 / 31 August 2010**

**Reporting of non-kiln operational summary of continuous measurements for the month March 2022**

| <b>Pollutant</b>   | <b>Release point</b> | <b>Daily average limit<br/>mg/m3</b> | <b>Maximum daily average<br/>mg/m3</b> | <b>Average of daily averages<br/>mg/m3</b> |
|--------------------|----------------------|--------------------------------------|----------------------------------------|--------------------------------------------|
| Particulate matter | A2                   | 20                                   | 7.35                                   | 5.31                                       |
|                    | A3                   | 20                                   | 3.92                                   | 2.49                                       |

Operator's comments:

Signed: Daniel Bound (Environmental coordinator) (via daniel.bound@tarmac.com)  
(authorised to sign as representative of Tarmac Cement and Lime Ltd)

Date: 11/04/2022