

# WATER SPOT CHECK SAMPLING

<b>Site Name:</b>	<b>Ffos-y-fran Land Reclamation Scheme</b>		
<b>Permit No:</b>	<b>EPR/DB3131AF</b>	<b>Month:</b>	<b>April 2022 (samples taken 26.04.22)</b>

## Reporting of emissions to water (other than to sewer)

Consent Number	Suspended Solids Consent limits	pH Consent limits	Date of Sample	Discharge Status	pH result	Susp solids result	Weather Conditions
AN0264601 (WC1 Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0264602 (WC1 Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
NPSWQD000674 (WI Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
NPSWQD002105 (WI Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
<b>AN0264501 (WB Final Effluent)</b>	<b>50 mg/l</b>	<b>5-9</b>	<b>26-04-22</b>	<b>Discharging</b>	<b>7.4</b>	<b>6</b>	<b>Dry</b>
AN0264502 (WB Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264603 (WC Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0274601 (WC Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0265001 (WG Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0265002 (WG Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264801 (WF Final Effluent)	50 mg/l	5-9	N/A	Not Discharging	N/A	N/A	
AN0264802 (WF Storm)	N/A	N/A	N/A	Not Discharging	N/A	N/A	
AN0264401 (WA Final Effluent)	50 mg/l	5-9	N/A	N/A	N/A	N/A	
AN0264402 (WA Storm)	N/A	N/A	N/A	N/A	N/A	N/A	

**Notes:**

**WA has not yet been constructed.**

**DP Sample taken 26-04-2022, pH 8.3, TSS <5 mg/l.**

Name	S. Woolmington	Position:	Engineer	Date:	24.6.22
------	----------------	-----------	----------	-------	---------