

Compliance Report

Company:Harsco Environmental Contact:Paul Roberts

Authorisation number (s):Lancing Booth Stack Monitor Q3 2022

No exceedances

From:01 Jul 22 00:47:54 To:01 Oct 22 00:47:54

Device 1 : Stack1 Dust Cal Factor: WARNING CAL FACTOR IS NOT CONSTANT Average:0.885 Averaging Period:1 hrs

Emission Limit: 20.00 INDmg/m3

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
01 Jul 22	0.16	0	pass	pass
02 Jul 22	4.48	0	pass	pass
03 Jul 22	0.13	0	pass	pass
04 Jul 22	0.09	0	pass	pass
05 Jul 22	14.35	0	pass	pass
06 Jul 22	9.80	0	pass	pass
07 Jul 22	0.88	0	pass	pass
08 Jul 22	0.47	0	pass	pass
09 Jul 22	0.01	0	pass	pass
10 Jul 22	0.01	0	pass	pass
11 Jul 22	0.01	0	pass	pass
12 Jul 22	7.12	0	pass	pass
13 Jul 22	1.88	0	pass	pass
14 Jul 22	16.77	0	pass	pass
15 Jul 22	14.04	0	pass	pass
16 Jul 22	0.19	0	pass	pass
17 Jul 22	0.31	0	pass	pass
18 Jul 22	18.51	0	pass	pass
19 Jul 22	17.47	0	pass	pass
20 Jul 22	7.10	0	pass	pass
21 Jul 22	8.88	0	pass	pass
22 Jul 22	9.34	0	pass	pass
23 Jul 22	4.54	0	pass	pass
24 Jul 22	4.45	0	pass	pass
25 Jul 22	4.50	0	pass	pass
26 Jul 22	11.99	0	pass	pass
27 Jul 22	6.48	0	pass	pass
28 Jul 22	7.36	0	pass	pass
29 Jul 22	0.14	0	pass	pass
30 Jul 22	4.30	0	pass	pass
31 Jul 22	4.42	0	pass	pass
01 Aug 22	5.13	0	pass	pass
02 Aug 22	4.35	0	pass	pass
03 Aug 22	2.85	0	pass	pass
04 Aug 22	5.71	0	pass	pass
05 Aug 22	7.28	0	pass	pass
06 Aug 22	0.16	0	pass	pass
07 Aug 22	0.08	0	pass	pass
08 Aug 22	11.33	0	pass	pass
09 Aug 22	8.62	0	pass	pass
10 Aug 22	0.28	0	pass	pass
11 Aug 22	0.15	0	pass	pass
12 Aug 22	11.41	0	pass	pass
13 Aug 22	0.19	0	pass	pass
14 Aug 22	0.09	0	pass	pass
15 Aug 22	8.39	0	pass	pass
16 Aug 22	12.12	0	pass	pass
17 Aug 22	4.33	0	pass	pass
18 Aug 22	4.52	0	pass	pass
19 Aug 22	12.07	0	pass	pass
20 Aug 22	0.09	0	pass	pass
21 Aug 22	0.06	0	pass	pass
22 Aug 22	0.11	0	pass	pass
23 Aug 22	0.04	0	pass	pass
24 Aug 22	4.61	0	pass	pass
25 Aug 22	0.12	0	pass	pass
26 Aug 22	0.71	0	pass	pass
27 Aug 22	0.03	0	pass	pass
28 Aug 22	0.01	0	pass	pass
29 Aug 22	0.01	0	pass	pass
30 Aug 22	0.01	0	pass	pass
31 Aug 22	0.02	0	pass	pass
01 Sep 22	0.01	0	pass	pass
02 Sep 22	0.02	0	pass	pass
03 Sep 22	0.14	0	pass	pass
04 Sep 22	4.49	0	pass	pass
05 Sep 22	4.95	0	pass	pass
06 Sep 22	4.74	0	pass	pass
07 Sep 22	4.83	0	pass	pass
08 Sep 22	0.64	0	pass	pass
09 Sep 22	4.59	0	pass	pass

Date	Max Value (INDmg/m3)	Number of failures	95% Compliance	Max < 150% Limit
10 Sep 22	1.01	0	pass	pass
11 Sep 22	0.01	0	pass	pass
12 Sep 22	0.01	0	pass	pass
13 Sep 22	0.02	0	pass	pass
14 Sep 22	0.01	0	pass	pass
15 Sep 22	0.01	0	pass	pass
16 Sep 22	0.01	0	pass	pass
17 Sep 22	0.01	0	pass	pass
18 Sep 22	0.01	0	pass	pass
19 Sep 22	0.01	0	pass	pass
20 Sep 22	0.01	0	pass	pass
21 Sep 22	0.01	0	pass	pass
22 Sep 22	4.01	0	pass	pass
23 Sep 22	4.82	0	pass	pass
24 Sep 22	0.07	0	pass	pass
25 Sep 22	0.12	0	pass	pass
26 Sep 22	4.71	0	pass	pass
27 Sep 22	0.13	0	pass	pass
28 Sep 22	0.10	0	pass	pass
29 Sep 22	4.76	0	pass	pass
30 Sep 22	0.13	0	pass	pass
01 Oct 22	0.15	0	pass	pass