

Permit Number:

EPR/BV74601D

Operator:

Nexperia Newport Limited

Facility:

Newport Semiconductor Plant

Form Number:

Sewer1 / 14/09/2020

Reporting of emissions to sewer for the period from 01/01/2022 to 30/06/2022

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
S1	Suspended solids	No limit set	Spot sample	Min. 15 mg/l Max. 61 mg/l	BS EN 872, BS 6068-2.54	18 th Mar 2022 @ 10.35 12 th Jan 2022 @ 12.32	Not Known
	Chemical oxygen demand	No limit set	Spot sample	Min. 50 mg/l Max. 582 mg/l	BS 6068-2.34	8 th Feb 2022 @ 11.35 12 th Jan 2022 @ 12.32	Not Known
	Flow	No limit set	Continuous reported as daily average	1051 m ³ /day	As agreed in writing with Natural Resources Wales	N/A - average	±4.37% (MCERTS)
	Copper	No limit set	Spot sample	<0.1 mg/l	BS EN ISO 15586:2003, BS 6068-2.84:2003	All samples <0.1 mg/l	Not known
	Nickel	No limit set	Spot sample	<0.1 mg/l	BS 6068-2.29, ISO 8288	All samples <0.1 mg/l	Not known
	Zinc	No limit set	Spot sample	<0.1 mg/l	BS 6068-2.29, ISO 8288	All samples <0.1 mg/l	Not known
	Chromium	No limit set	Spot sample	<0.1 mg/l	BS EN 1233, BS 6068-2.38, ISO 11083	All samples <0.1 mg/l	Not known
	Sulphate	No limit set	Spot sample	Min. 164 mg/l Max. 796 mg/l	SCA Blue Book 136 ISBN 0117522406	07 th June 2022 @ 11.20 09 th May 2022 @ 12.11	Not known

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
	pH	Minimum 6, Maximum 11	Continuous reported as maximum and minimum over reporting period	Min 6.0 Max 9.6	SCA Blue Book 14 ISBN 0117514284 or agreed in writing with Natural Resources Wales	13 th Jan 2022 @ 06.59 21 st Jun 2022 @ 13.57	±pH0.05

Notes:

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. Where uncertainty figures are 'not known' this is because the analysis is carried out by Welsh Water and they do not provide uncertainty information
- [5] For 95 % of all measured values according to look up table
- [6] For pH, figures known to relate to times where maintenance was being carried out (pH probe buffering) have been excluded as these are not true readings

Signed  Date: 22/7/22
(Authorised to sign as representative of Operator)