

Permit Number: EPR/BV9683IH

Operator: Dunbia (UK)

Facility: Teify Park Abattoir and Meat Processing Plant

Form Number: Q2 Water

Reporting of emissions to water (other than to sewer) and land for the period from 01/04/2022 to 30/06/2022

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
W2	Total suspended solids	50 mg/l	24 hour flow	40.1 mg/l	HMSO ISBN 011751957X	10 th May 2022	13.4%
W2	pH	6-9	24 hour flow	7.6 – Min 8.5 - Max	On-line pH electrode/ meter	05 th April 2022 19 th April 2022	9%
W2	BOD	30 mg/l	24 hour flow	3.57 mg/l	BS 6068-250:1995	19 th April 2022	16%
W2	Ammonia	10mg/l	24 hour flow	0.4 mg/l	BSENISO 11732:1997	28 th June 2022	6.6%
W2	Volume/flow rate	630m ³ /day	24 hour flow	386 m ³ /day - Max	On-line flow meter	23 rd June 2022	-

The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases, the principal technique is stated, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

Signed
(Authorised to sign as representative of Operator)

Date... 14/07/2022