

## RELEASES INTO SEWER

Release Summary for Quarter ...3..... Year ...2022.....

Operator Vale Europe Ltd.,  
Permit No. BL 4567

Release Point: S1  
Location: Clydach SA6 5QR

Parameter	3 Monthly Maxima *	3 Monthly Mean	Limit
Temperature °C	25	18.3	43
Flow m <sup>3</sup> /hour	3.7	3.1	6.82
Flow m <sup>3</sup> /day	90	75.3	120
Suspended Solids mg/l	10	10	400
Fixed Ammonia (as N) mg/l	1960	1352	4000
Free Ammonia (as N) mg/l	-	-	100
pH Maximum	7.2	6.8	10
pH Minimum	6.4	6.8	5

\* in the case of pH Minimum, the *minimum* pH figures should be reported.

Date: As per email

Signed on behalf of Vale Inco Europe Ltd.,

Bob Fussell

Form S1 dated 27/10/03

Email to: industryregulation.swales@cyfoethnaturiolcymru.gov.uk