

Aug 2022

Day	Downtime	Availability	Rationale
1	0	100.00%	
2	0	100.00%	
3	0	100.00%	
4	1.5	93.75%	DCS OS Server crashed, spare unit configured but issues with PLC comms delayed restart.
5	22	8.33%	
6	0	100.00%	
7	0	100.00%	
8	0	100.00%	
9	0	100.00%	
10	6.5	72.92%	Plant initially tripped due to unable to start oil burner when CC3 runner jammed unit stopping fuel. Upon restart experienced live steam trip, plant restarted ok.
11	0	100.00%	
12	0	100.00%	
13	0	100.00%	
14	0	100.00%	
15	0	100.00%	
16	0	100.00%	
17	0	100.00%	
18	0	100.00%	
19	4	83.33%	
20	0	100.00%	
21	0	100.00%	
22	0	100.00%	
23	0	100.00%	
24	0	100.00%	
25	0	100.00%	
26	0	100.00%	
27	23	4.17%	Plant on Annual Outage
28	24	0.00%	
29	24	0.00%	
30	24	0.00%	
31	24	0.00%	
Month	153	79.44%	