

July 2022

Day	Downtime	Availability	Rationale
1	0	100.00%	
2	0	100.00%	
3	0	100.00%	
4	0	100.00%	
5	0	100.00%	
6	0	100.00%	
7	0	100.00%	
8	0	100.00%	
9	0	100.00%	
10	0	100.00%	
11	0	100.00%	
12	0	100.00%	
13	0	100.00%	
14	0	100.00%	
15	0	100.00%	
16	0	100.00%	
17	0	100.00%	
18	0	100.00%	
19	0	100.00%	
20	10.5	56.25%	Blinded filters and Superheater tube leak
21	24	0.00%	Superheaters 2 and 4 Tube repairs
22	24	0.00%	
23	24	0.00%	
24	24	0.00%	
25	24	0.00%	
26	20	16.67%	Plant start-up, blockages on CRI system
27	0	100.00%	
28	0	100.00%	
29	0	100.00%	
30	1	95.83%	Boiler tripped due to live steam temperature
31	0	100.00%	
Month	151.5	79.64%	