

Air Products (BR) Limited
Queensway, Spencer Works,
Llanwern, Newport,
South Wales
NP19 4QX

Telephone Plant:	(0)1633 281614
Fax Plant	(0)1633 277191
Telephone Plant Manager	(0)1633 273405
Fax Plant Manager	(0)1932 259094

29/07/2022.

Natural Resources Wales
Rivers House
St Mellons Business Park
St Mellons
Cardiff
CF3 0EY

Attention: Dr Gareth Richards.

Re IPPC Permit number BL 2459.

Dear Dr Gareth Richards.


Please find enclosed:

Releases to Water, quarter ending June 2022.

Yours sincerely



T C Ryan.
Plant Manager

	HYDROGEN PLANT LLANWERN FACILITY	PAGE 1 of 1
---	---	--------------------

SCHEDULE 1

Operator **Air Products (BR) Ltd**
Location **Hydrogen Plant, Llanwern**
Permit Number **BL2459**

Form S3/W (11/07/2022)			
Release point	Substance	Measured	Limit
W1	Suspended solids (mg l ⁻¹)	6.0	100
	Oil and grease (mg l ⁻¹)	<1	5
	pH maximum	8.2	10
	pH minimum	8.2	5

Date sampled: 11 07 2022.

Part A

Regarding the late sampling of our effluent sample.
The sample was taken on the 11th of July after it was brought to my attention that the sample should have been taken before the 30th of June.
In January our water treatment company appointed a new local account manager also our local water treatment company technician left as well.
The new people did not read the contract correctly and the effluent samples were missed.

Part B

I have brought this to the attention of the water treatment company and their staff have now read the contract and understand our contract and our sampling needs.

T C Ryan.
Plant Manager

