

Permit Number: EPR/BL3986ID

Operator: Tarmac Cement and Lime Ltd

Installation: Aberthaw Works

Form number: Air 10 / 31 August 2010

Reporting of non-kiln operational summary of continuous measurements for the month June 2022

Pollutant	Release point	Daily average limit mg/m3	Maximum daily average mg/m3	Average of daily averages mg/m3
Particulate matter	A2	20	6.39	3.99
	A3	20	9.67	5.81

Operator's comments:

Signed: Daniel Bound (Environmental coordinator) (via daniel.bound@tarmac.com)
(authorised to sign as representative of Tarmac Cement and Lime Ltd)

Date: 1/07/2022