

Permit Reference Number: KP3135KV

Operator: The Royal Mint Ltd

Facility: The Royal Mint

Form Number: Sewer I 02/08/22

Reporting of Emissions to Sewer for the period from: April to June 2022 (Quarter 2).

Emission Point:	Substance / Parameter:	Emission Limit Value:	Result: [1]	Test Method: [2]	Sample Date and Times [3]	Accreditation / Certification [4]
SI	Free cyanide	0.2 mg/l	0.21 mg/l * Remaining results in the period < 0.5 mg/l	Determination of Free Cyanide in water by Continuous Flow	20.04.22 – 01:00hrs spot sample.	UKAS = Methodology accredited to ISO/IEC 17025:2017
SI	Copper and its compounds	1.0 mg/l	0.186 mg/l	Determination of Metals in water by ICP-OES	21.06.22 – 07:10hrs spot sample.	UKAS = Methodology accredited to ISO/IEC 17025:2017
SI	pH	6 – 11	8.7 – 9.3	Determination of pH in water by pH meter.	20.04.22 – 01:00hrs & 21.06.22 – 07:10hrs spot samples.	UKAS = Methodology accredited to ISO/IEC 17025:2017

* Reading reported to NRW via schedule 5 notification 16th May 2022

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the “minimum – maximum” measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases, the principal technique is stated, e.g., gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed  Date 2nd August 2022
(Authorised to sign as representative of the Operator)