

Notice of variation with introductory note

Environmental Permitting (England & Wales) Regulations 2016

Tradebe Healthcare National Limited

**Wrexham Clinical Waste Treatment
Facility (Incinerator)
Marlborough Road
Wrexham Industrial Estate
Wrexham
LL13 9RJ**

Variation number
EPR/WP3836ZF/V004

Permit number
EPR/WP3836ZF

Wrexham Clinical Waste Treatment Facility (Incinerator)

Permit number EPR/WP3836ZF

Introductory note

This introductory note does not form a part of the notice

The following notice gives notice of the variation of an environmental permit.

This NRW initiated variation amends permit condition 2.1.7 and confirms the combustion temperature compliance requirements for the installation.

The schedules specify the changes made to the original permit.

The status log of the permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit		
Description	Date	Comments
Application AP3538SM (EPR/AP3538SM/A001)	Duly made 21/03/05	
Additional information received	06/09/05	
Additional information received	08/12/05	
Permit determined (EPR/AP3538SM)	14/12/05	
Variation application GP3335MA (EPR/AP3538SM/V002)	Duly Made 17/10/06	
Variation Notice issued (EPR/AP3538SM)	15/12/06	
Variation Notice VP3739XC issued (EPR/AP3538SM)	22/01/08	
Application EPR/MP3239FQ/T001 (full transfer of permit AP3538SM)	Duly Made 13/04/11	Application to transfer the permit in full to SITA UK Limited.
Transfer determined EPR/MP3239FQ	12/05/11	Full transfer of permit complete.
Variation application EPR/MP3239FQ/V002	Duly made 12/05/11	Application to vary the permit
Application EPR/WP3836ZF/T001 (full transfer of permit EPR/MP3239FQ)	Duly made 04/02/13	Application to transfer the permit in full to Polkacrest Limited.

Status log of the permit		
Description	Date	Comments
Transfer determined EPR/WP3836ZF/T001	04/03/13	Full transfer of permit complete.
Notified of change of company name	17/12/14	Name changed to Tradebe Healthcare National Limited
Variation issued EPR/WP3836ZF	14/01/14	Varied permit issued to Tradebe Healthcare National Limited
Notified of amendment to terms of the existing permit EPR/WP3836ZF/V003	09/03/17	The addition to the existing permit of European Waste Code input types 16 03 03, 16 03 04, 16 03 05, 16 03 06, 18 02 01, 19 02 09 & 19 02 10 to Permitted Waste Types table.
Variation issued EPR/WP3836ZF/V003	26/06/2017	Varied permit issued to Tradebe Healthcare National Limited
Regulation 61(1) Notice sent to the Operator	15/06/2021	Issue of a Notice under Regulation 61(1) of the EPR. Natural Resources Wales initiated review and variation to vary the permit following the publication of the revised Best Available Techniques (BAT) Reference Document (BRef) for waste incineration
Regulation 61(1) Notice response	14/12/2021	Response received from the operator.
Request review of previous submission and if necessary additional information.	08/03/2022	
Additional information received	05/04/2022	
NRW initiated Variation determined EPR/WP3836ZF/V004	01/11/2022	Variation confirming combustion temperature compliance requirements

End of introductory note

Notice of variation

Environmental Permitting (England and Wales) Regulations 2016

The Natural Resources Body for Wales (“Natural Resources Wales”) in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2016 varies

Permit number
EPR/WP3836ZF

issued to:
Tradebe Healthcare National Limited (“the operator”)

whose registered office is

**Atlas House
Third Avenue
Globe Park
Marlow
Buckinghamshire
SL7 1EY**

company registration number 03882534

to operate a regulated facility at

**Wrexham Clinical Waste Treatment Facility (Incinerator)
Marlborough Road
Wrexham Industrial Estate
Wrexham
LL13 9RJ**

to the extent set out in the schedules.

The notice shall take effect from 01/11/2022

Signed

Date

Holly Noble

01/11/2022

Authorised on behalf of Natural Resources Wales

Schedule 1 – conditions to be deleted

None

Schedule 2 – conditions to be amended

The following conditions are amended as detailed, following an NRW initiated variation.

2.1.7 is amended and now reads as follows:

2.1.7 Waste shall not be charged if:

- (a) the secondary combustion chamber temperature is below 850 °C,
- (b) it is hazardous waste with a hazardous halogenated organic content of more than 1% (expressed as chlorine) and the secondary combustion chamber temperature is below 1,100 °C.
- (c) it is cytotoxic or cytostatic waste and the secondary combustion chamber temperature is below 1,000 °C
- (d) any continuous emission limit value in Table 2.2.2(a) is exceeded during abnormal operation; or
- (e) any continuous emission limit value in Table 2.2.2 is exceeded, other than during abnormal operation; or
- (f) continuous emission monitors to demonstrate compliance with any continuous emission limit value in Table 2.2.2 are unavailable other than during abnormal operation; or
- (g) there is a stoppage, disturbance or failure of the activated carbon abatement system, other than during abnormal operation; or
- (h) continuous emission monitors to demonstrate compliance with the emission limit values for particulates, TOC or CO in Table 2.2.2 and Table 2.2.2(a) are unavailable unless alternative techniques, as agreed in writing with Natural Resources Wales, are used to demonstrate compliance with those emission limit values; or
- (i) the oxygen level is below, or falls below 6% (wet) by volume; or
- (j) The emergency relief vent is open.

Schedule 3 – conditions to be added

None