

	Form No: <b>DLNG-FRM-EV-010</b>	Revision: 1
		Issue Date: 13/07/16
		Review Date: 12/07/19
		Pages: 1 of 1
Form Title: <b>NRW Quarterly Flaring /Venting Form</b>		

Releases to Air :

Operational Parameters: Summary for Quarter 3

- 01/07/2022 TO 30/09/2022

Operator Dragon LNG Ltd  
Location Waterston, Milford Haven, SA73 1DR  
Authorisation / Variation EPR/AP3136UA/V005

<b>Methane Venting / Flaring</b>					
Date of Venting / Flaring	Emission Point	Duration (h)	Estimated loss (t)	Accumulated loss for year to date (t)	Reference to investigation report
<b>Q1</b>	N/A	N/A	N/A	N/A	N/A
<b>Q2 – 13/04/2022</b>	PDT-174-0798 transmitter leak	24 hours	0.0299	0.0299	DLNG-I-1021
<b>Q2- 07/06/2022</b>	XV821-0073 LP Pump P821-001 Actuator leak	15 minutes	0.007	0.0369	DLNG-I-1043
<b>Q3- 11/07/2022</b>	XV-174-4511 SCV 6 bleed valve	20 seconds	0.004	0.0409	DLNG-I-1059
<b>Q3- 28/07/2022</b>	A7 Flare - due to RP Trip	10 minutes	0.061	0.1019	DLNG-I-1065

*Signed on behalf of the Operator by*

Name: Priscilla Wilson  
Designation: HSE Lead  
Date: 28/10/2022