

Date of form 13/10/14

Date of form 13/10/14

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: **Sept 2021**

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator

P. Williams

Date 26/10/2020

Schedule 3 - Form Number: W1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [Sept 2021](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	04/07/2021
Suspended Solids mg/l	50	8.0	4.0	04/07/2021
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	05/08/2021
Suspended Solids mg/l	50	2.0	2.0	05/08/2021
Mineral oil and hydrocarbons mg/l	5	0.98	0.6	02/09/2021 28/09/2021
Suspended Solids mg/l	50	11.0	9.0	02/09/2021 28/09/2021

Signed on behalf of the Operator



Date 26/10/2021

Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [Sept 2021](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.3	7.6	10.06	10.9
Total suspended solids mg/l	600	11	29.6	51	54
Total chemical oxygen demand (COD) mg/l	3600	184	282.1	396.4	421
Free or emulsified grease or oil mg/l	100	1.24	6.0	9.402	11.4
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.03	0.025
Dissolved oxygen mg/l	-	0.5	2.1	8.68	8.8
Ammoniacal nitrogen as N mg/l	-	2.65	10.0	21.12	25.5
Daily flow m ³ /day	800	28.7	524.0	775.2	809.2
Maximum flow m ³ /h	34	1.2	21.8	32.3	33.7

Signed on behalf of the Operator



Date 26/10/21

Permit EPR/AP3433ES

Date of form 13/10/14